



THE EXACT CALCULATION OF THE SIZE OF THE CABLES WILL DEPEND ON THE DISTANCE. IT SHALL BE THE ENTIRE RESPONSABILITY OF THE COMPANY THAT WILL CARRY OUT THE WORK

ALL OF THE CABLES SHOULD BE OF 1000 R02 V TYPE. THE MAIN POWER SUPPLY SHOULD BE PROTECTED WITH A 300 mA CIRCUIT BREAKER.

Index	Date	Type of modification	Requested by
<b>CONNECTION OF FP2 STANDARD ELECTRICAL CABLES</b>			
Scale : <u>—</u>		Created for: <u>NAME OF CUSTOMER</u>	
Date : <u>07 MAI 08</u>	Drawn by : <u>FLORES BE</u>	Material : <u>—</u>	
FORMAT : <u>A3</u>	Checked by : <u>—</u>	Treatment : <u>—</u>	
Weight : <u>—</u>	TB no. : <u>00000.000</u>	Access path : <u>—</u>	
Do not modify manually	SYSTEM: AUTOCAD 2000	C:\	



**FLUIDES PETROLE SERVICES**  
 Tous Travaux GPL  
 ZA 16 Boissonnette - 07340 PEAUGRES  
 Tél: +33 (0)4 75 32 53 01 - Fax +33 (0)4 75 32 52 87  
 RCS ANNONAY 441 872 587 - APE 743 B

<b>C 0011</b>	<b>1/1</b>
---------------	------------

THIS DOCUMENT MAY NOT BE REPRODUCED OR COMMUNICATED WITHOUT FPS's AUTHORIZATION